

MANAGERS REPORT FOR AUGUST 19,08

The overflow wet well at pump station 19 is finished and in operation to prevent any future over flows from that station. It works very well and will prevent future spills.

At station 16 after Mr. Snyder installed the vacuum lift pump system, the discharge piping was redone. That proved to be a nightmare as there was no way to shut off any backflow from the almost two mile uphill discharge line in case of trouble and the emergency standby pump had been removed as not needed. The crew has now corrected that problem with new piping with shutoff and check valves and the overflow standby pump is now back in operation.

Work at the new treatment plant is on schedule and things are looking good for putting liquid into the first aeration pond by August 22, 2008.

Work will start on new stations 22 & 24 by the end of this month with station 22 starting first as it has tremendous ground water intrusion which causes to have very high T.D.S lab reports (salt) .

On Monday Aug. 11,2008 I toured the Arroyo Salada wash to see if there was any signs of water in the area outside the old ponds as we now have two of those ponds completely dry and all the others are considerably lower. The wash was dry in that area, but up the wash about a mile there was standing water for another couple of miles, all the way past the double pole line where I left the wash. Weekend mountain rain.


Tom Cannell General Manager